



0134



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आज़ादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/2025/NDZ/ 305

Dated: 01 / 05 / 2025

To,

The Principal,  
Vidya Bal Bhawan Public School,  
Master Block, Shakarpur, Delhi-110092.  
Delhi-110092.

**Subject: - Regarding Renewal of FSC in r/o Vidya Bal Bhawan Public School, Master Block, Shakarpur, Delhi-110092.**

Sir,

Please refer to your Outdoor Dairy No.432 dated 09/04/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on dated 19/04/2025 and observed that the shortcomings issued by this department vide letter no. F6/DFS/MS/School/2020/NDZ/159 dated 05/03/2020 (copy enclosed) have still not complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Enclosed: as above

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi - 110002.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

C-28

No. F6/DFS/MS/School/2020/NDZ/159

Dated:- 05/03/2020

To,

The Manager,  
Vidya Bal Bhawan Public School,  
Master Block, Shakarpur, Delhi-92.

Sub:-Regarding issue of NOC in r/o Vidya Bal Bhawan Public School, Master Block, Shakarpur, Delhi-92.

Sir,

Please refer to your letter No. VBBPS/2019-20/975 dated 23/11/19 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection of the above said school building from fire safety point of view. During the course of inspection following shortcoming were observed:-

1. Access to school building road width 4.5 meter provided in place of 6 meter.

In view of above, the building cannot be considered for issuance of fire safety certificate.

Yours Faithfully

(Atul Garg)

Director

Delhi Fire Service

07/03