GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6/DFS/MS/2025/School/WZ/965

08/08/2025 Dated

FIRE SAFETY CERTIFICATE

Certified that the Vidya Jyoti Shiksha Sadan located at Daryapur Kalan, Delhi-110039 comprised of Ground floor only was issued FSC by this department vide letter No F6 /DFS/MS/2022/School/WZ/967 dated 06.09.2022. The premises was re-inspected by the officer concerned of this department on 21.07.2025 in the presence of Smt. Suman Lata (Principal), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ... 0.8 0.8 2025. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 08. 0.8. 2.025 at New Delhi by

(Virendra Singh) Chief Fire Officer MA

Copy to:-

- 1. The Director of Education, Govt. of NCT of Delhi, Old Secretriat, Delhi.
- 2. The Principal, Vidya Jyoti Shiksha Sadan located at Daryapur Kalan, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock.
- 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

1. Name & address of the building : INSPECTION REPORT

2. Type of Occupancy
3. Building Comprised of Vidya Jyoti Shiksha Sadan located at Daryapur Kalan, Delhi- 110039.

 Building Comprised of
 Type of Case
 Details of Previous NOC
 Fire Safety directives letter No
 Date of inspection
 Name of Inspecting Officer
 Name and designation of officers Ground floor only Renewal

F6/DFS/MS/2022/School/WZ/967 dated 06/09/2022 DOE circular No. 3298-3398 dated 01/03/2011

21/07/2025 R.K.Sinha, ADO (BW) From the building side

No.	Minimum Standards on fire	Outdoor Diary No. 319	2 dated 27/06/2025			
1.	prevention and fire safety U/R 33 Access to building	DOE Requirement	Provided at site	Remarks		
	Road width	Acquirement		MR/NMF		
	Gate width	6 m	Provided			
	Width of internal read	4.5 m	Directly Accessible	MR		
2.	Number, Width, Type & Arrangen	NA	NA NA	MR NA		
	Number of staircases					
	Upper Floors	NA	NIA			
	Basements	NA	NA NA	NA		
	Width of staircases		NA	NA		
	Upper Floor	NA	NA T			
	Basements	NA	NA NA	NA		
	Protection of exits		NA	NA		
	Fire check door	NA	N/A	11		
	Pressurization	NA	NA NA	NA		
	No. of continuous staircases to	E.M. B.	NA	NA		
	terrace	NA	NA	NA		
	Width of Corridor	NA	NA	NA		
	Door Size	l m	Provided			
3.	Compartmentation	10	- 10 1 dou	MR		
	Fire check door	NA	NA			
	Sealing of electrical shafts	NA	NA NA	NA		
	Fire Rating of shaft door	NA	W. W. O.	NA		
	Water Curtain	NA NA	NA NA	NA		
	Fire Dampers	NA	NA NA	NA		
١.	Smoke Management System NA NA					
	Basements	NA NA	NA			
	Upper floors	NA .	And China	NA		
	Opper moors		NA	NA		
	Fire Extinguishers					
	Total numbers	04	Provided	MR		
	Types	ABC / CO2Type	Provided	MR		
	IS marking	Required	Provided	MR		
	First-Aid Hose Reels					
	Total numbers on each floor	NA NA	NA NA	NA		
	Length of hose reel hose	NA Na	27.00-0	NA		
	Nozzle diameter	NA	NA	NA		
	Automatic fire detection and alarming system					
-	Type of detectors	NA	NA	NA		
-	Location of Main Panel	NA	NA	NA		
-	Location of Main Lance	NA	NA	NA		
-	Location of Repeater Panel	NA	NA	NA		
	Alternate source of power	NA	NA			
	Hooters' Location	a a		NA		

N-14

8.	Mon	N-14			
9.	MOEFA				
	Public Address System	NA	NA		
10.		NA	NA		
	Automatic Sprinkler System			1	
	Basement				
	Ground Floor	NA	NA		
	Sprinkler above false ceiling	NA	NA NA	N	
11.	Internal Hydrants	NA	NA NA	N	
			INA	N.	
	Size of riser/down-comer				
	Trumber of hydrante need	NA	NA		
12.	TIOSC DOX	NA	NA NA	N/	
14.	Yard Hydrants	NA	NA NA	NA NA	
	Total		INA	NA	
	Total number of hydrants Hose Box	NA			
13.	Pumping A	NA NA	NA	774	
×.	Pumping Arrangements	NA	NA	NA NA	
	Ground Level			INA	
	Discharge of main Pump				
	Head of Mai	NA			
	Head of Main pump	NA	NA NA	NA	
	Number of main pumps	(6.5)	INA	NA	
	Jockey Pump out put	NA	NA		
	Jockey pump head	NA	NA	NA	
	Standby Pump out put	NA NA	NA	NA NA	
	Standby Pump Head	NA NA	NA	NA NA	
	Auto Starting/Manual Stopping	NA NA	NA	NA NA	
	Pump House Access	NA	NA	NA NA	
	TAOUSE ACCESS	NA	NA	NA NA	
	Terrace level			IVA	
	Discharge of pump				
		NA	NA		
	Head of the pump	NA	NA NA	NA	
	Power Supply	27.1		NA	
_	Auto Starting of pump	NA NA	NA	NA	
14.	Captive Water Storage for fire fighting				
	Underground tools				
	Draw-off connection	NA NA	NA	NA	
	Fire service inlet		NA	NA	
	Access to tank	NA NA	NA	NA	
	Overhead Tank capacity	NA NA	NA	NA	
5.	Exit Signage.	NA NA	NA	NA	
6.		INA	NA	NA	
0.	Provision of Lifts.				
	Pressurization of Lift Shaft	NA	NA	NA	
	Pressurization of Lift lobby	NA	NA	NA NA	
	Communication In lift Car	NA	NA	NA NA	
	Fireman's Grounding Switch	NA	NA	NA NA	
177	Lift Signage	NA	NA	NA NA	
	Standby power supply	NA NA	NA NA	NA NA	
				W.	
8.	Refuge Area.				
	Total Area	NA	NA	NA	
	Location	NA	NA ·	NA	
9.	Fire Control Room				
1			NA	NA	

PA System Panel	NA	NIA	
Battery backup	NA	NA	NA NA
	NA	NA	NA
Building Floor Plans		NA	NA
U. Special Fire Product	NA	NA	
Protection of special Risks, if a	for NA	500000	NA
pecial Risks, if a	ny:	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2022/School/WZ/967 dated 06/09/2022.

> Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.

22/07/20

Theter in Modpler Sond