

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/26

No. F6/DFS/MS/NDZ/2025/ 490

Dated: 06/06/2025

To

The Principal

Vidyadeep Public School, P-110-114, Phase-4,
Lok Vihar, Shiv Vihar, Karawal Nagar, Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o Vidyadeep Public School, P-110-114, Phase-4, Lok Vihar, Shiv Vihar, Karawal Nagar, Delhi-110094.

Sir,

This has reference to your letter received through email dated 05/05/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 24/05/2025 in the presence of Mr. Devat Ram Singh (Head Master) to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present building comprised of Ground plus three upper floors.

Following shortcomings were observed during the time of inspection:-

1. Hose reel host is provided but found not functional.
2. Fire Pump is provided but found not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "J" are as under :

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home/Forms

Yours faithfully



(VIRENDERA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

dc

Copy to:-

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.