



e/15



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2025/School/ WZ/1318

Dated: 17/11/2025

FIRE SAFETY CERTIFICATE

Certified that the Virmani Public School located at Roop Nagar, Delhi-110007 comprised of Ground & First Floor only owned/ occupied by Virmani Public School was issued FSC by this department vide letter No. F6/DFS/MS/2022/NWZ/1150 dated 18/10/2022. The premises was re-inspected by the officer concerned of this department on 03/11/2025 in presence of Smt. Rekha Sharma (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 262-362 dated 17/01/2005 and the building/ premise is fit for occupancy class **"Group B Educational (School) for ground & first floor only"** with effect from17.11.2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on17/11/2025 at New Delhi by.


S.K. Dua

Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

4. The Deputy Director of Education, Civil Line Zone, MCD, 16, Rajpura Road, Delhi.
5. The Principal, Virmani Public School located at Roop Nagar, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Virmani Public School, Roop Nagar, Delhi-110007.
2. Type of Occupancy : Educational
3. Composition of building : Ground & First Floor Only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2022/NWZ/1150 Dated: 18/10/2022
6. Fire Safety directives letter No : Director of education circular dated 17/01/2005
7. Date of inspection : 03/11/2025
8. Name of the Inspecting Officers : ADO (Rohini)
9. Name and designation of officers
from the building side : Smt. Rekha Sharma (Principal)
10. Year of Construction : 2000
11. Applicant's letter No. : Online e-mail Dated: 30/10/2025

	Minimum Standards on fire prevention and fire safety U/R 33	D. O. E Circular dated: 17.01.2005 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.25m each	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	08nos	08nos	MR
	• Types	ABC/Co2	ABC-08	MR
	• ISI marking	Yes	Yes	MR

By +

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none">Total numbers on each floorLength of hose reel hoseNozzle diameter	01	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none">Type of detectorsLocation of Main PanelLocation of Repeater PanelAlternate source of powerHooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none">BasementUpper FloorSprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none">Size of riser/down-comerNumber of hydrants per floorHose Box	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none">Total number of hydrantsHose Box	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none">Ground Level<ul style="list-style-type: none">Discharge of main PumpHead of Main pumpNumber of main pumpsJockey Pump out putJockey pump headStandby Pump out putStandby Pump HeadAuto Starting/ Manual stoppingPump House Access	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none">Terrace level<ul style="list-style-type: none">Discharge of pumpHead of the pumpPower SupplyAuto Starting of pump	450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none">Underground tank capacityDraw-off connectionFire service inlet	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

	<ul style="list-style-type: none"> ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		3,000 LTR	3,000 LTR	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2005, **it is recommended for renewal** of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/School/2022/NWZ/1150 Dated: 18/10/2022.

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO (Rohini)

DO (NW)

Dy. CEO (002)

Principal Director

Dy. CEO (002)

ADO (Rohini)

F.T. please.