

C-52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2025/ 320

Dated 11/07/25

To,

The Commissioner, MCD,  
Civic Centre, Minto Road,  
New Delhi.

Sub: Inspection report in respect of Visa Guest House, located at 9834/9835, Gali No.6  
Multani Dhanda, Paharganj, New Delhi- 110055.

Sir,

Please refer to your Online Application ID. No. 2025060909850 dated 12/06/2025, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 04/07/2025 in the presence of Sh. Sandeep Chaudhary to check the Fire safety arrangements.

During inspection, it was observed that the Guest house is running at Ground + 02 Upper Floors, in a building comprised of ground + 02 upper floors, ground floor (reception), 1<sup>st</sup> floor to 2<sup>nd</sup> floor (07 guest rooms at each floor), (total 14 guest rooms), was issued FSC vide letter no. F6/DFS/MS/GH/NDZ/2022/228 dated 17/05/2022. Fire safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, MOEFA, Pumping Arrangement & Exit Signage etc, are provided. However, following shortcomings were observed:-

1. Automatic Fire Detection system is provided but not functional.
2. MOEFA is provided but not functional.
3. First aid Hose Reels are provided but not functional.

In view of above shortcomings, the application for renewal fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Copy to: -

1. The Owner/Occupier, M/s. Visa Guest House, located at 9834/9835, Gali No.6 Multani Dhanda, Paharganj, New Delhi- 110055. Online Application ID. No. 2025060909850 dated 12/06/2025.