

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/2025/SZ/ *School 214*  
To

Dated: *12* / *04* / 2025

The Dy. Director (L&I) Bldg,  
Delhi Development Authority,  
Vikas Sadan INA,  
New Delhi 110023.

Sub: Regarding issuance of FSC in r/o M/s Vishwa Bharti Public School, at Plot No 1, Sector-6, Dwarka, New Delhi.

Sir,

This has reference to your letter Online ID DW6/0185/2021\_OCC dated 20/03/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09.04.2025 in the presence of Ms. Prabha Gupta (Principal) Mr. Jatin Kapoor (Admin Officer) & Mr. Virendra Aggarwal (Engineer) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The width of some of the staircases is less than of 1.50 mtr.
2. The 6 mtr wide motorable road with turning radius 9 mtr not provided. The Motorable road shall be capable to withhold the load bearing capacity of 45 tone including drainage slab cover available on the road.
3. Fire check door not provided at some places as marked on building plans.
4. Sealing of Shaft not provided.
5. Diesel pumps capacity 2280 LPM not on auto mode.
6. Fire Control room not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

*Virendra Singh*  
*11/4/2025*  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

*9/4*