

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/Motel/2024/SZ/ 23  
To

Dated 13/01/2025

The Addl. Commission of Police,  
Lic/Branch, 1<sup>st</sup> Floor PS Defence Colony,  
New Delhi 110049

**Sub:** - Regarding issuance of fire safety certificate in r/o Vista Motel, (M/s Vista Hospitality Pvt. Ltd) 162, M. G Road, New Delhi- 110030

Sir,

This has reference to with letter no nil dated nil received through outdoor diary not 10418 dated 17/12/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09.01.2025 in the presence of Mr. Raj Kishor to verify the fire safety measures installed in the building and observed that the building is comprised of Basement (Sealed) ground & first floors only. During inspection, following points were observed:

- 1 First Aid Hose reel provided but found not working.
- 2 Automatic Sprinkler System provided but found not working.
- 3 Internal & Yard Hydrants provided but found not working.
- 4 Discharge of main pump, Terrace level pump and jokey pump not working.
- 5 Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg Department) South Zone, MCD, Green Park, Aurobindo Marg, New Delhi 110016