

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/Motel/2025/SZ/ 212
To

Dated 07/05 /2025

The Addl. Commission of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o Vista Motel, (M/s Vista Hospitality Pvt. Ltd) 162, M. G Road, New Delhi- 110030

Sir,

This has reference to with letter no nil dated nil received through DFS outdoor diary not 15004 dated 26/03/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 30.04.2025 in the presence of Mr. Prem Sharma (Accounts) to verify the fire safety measures installed in the building and observed that the building is comprised of Basement (Sealed) ground & first floors only. During inspection, following points were observed:

- 1 Basement found closed.
- 2 Rear side exit door found blocked.
- 3 Smoke Management system provided but found not working.
- 4 Automatic Sprinkler System (Concealed type) block at some places.
- 5 Carbon Monoxide detector not provided.
- 6 Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg Department) MCD, Green Park, Aurobindo Marg, New Delhi 110016