

21143

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2025/ 107

Dated: 04/03/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Vivek Guest House situated at 1534-50, Main Bazar, Pahar Ganj, New Delhi, comprised of Ground + Mezzanine + 04 upper floors: Ground floor - (04 guest rooms + reception + 01 office + lobby + internet café), mezz. floor - (other portion in other use), 1st floor - (11 guest rooms), 2nd floor - (22 guest rooms), 3rd & 4th floor - (not in use), total 37 guest rooms upto second floor only was granted FSC by this department vide letter no. F6/DFS/MS/GH/NDZ/2022/149 dated 15.03.2022. The building/premises was re-inspected by officer concerned of this department on 22.02.2025 in presence of Mr. Vivek Juneja (Proprietor) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. The owner has submitted an affidavit on 24.02.2025 stating not to use any floor above second floor for any purpose. Accordingly, the premises is fit for occupancy of class "Residential" (Sub Division-A-1), ground floor - (04 guest rooms), 1st floor - (11 guest rooms) & 2nd floor - (22 guest rooms) for total 37 guest rooms upto 2nd floor only, with effect from ...04/03/2025... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 subject to condition printed below.

Issued on ...04/03/2025... at New Delhi by


(Arun Garg)
Director
Delhi Fire Service
Tel: 011-23414000
012
03/03

Copy to:-

1. The Commissioner, MCD:- to kindly ensure the occupancy as detailed above & deviation, if any.
2. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2025021701972 dated 17.02.2025.
3. The Licensee, M/s Vivek Guest House at 1534-50, Main Bazar, Pahar Ganj, New Delhi.

Conditions for the validity of fire safety certificate

1. This FSC is valid for ground, 1st & 2nd floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
10. The occupancy of above 2nd floor not allowed as per clause 7.31 in UBBL-2016.

INSPECTION REPORT

1	Name & address of the building	M/s Vivek Guest House at 1534-50, Main Bazar, Pahar Ganj, New Delhi.		
2	Building is comprised of	(Ground + Mezzanine + 04 upper floors) Ground floor – (04 guest rooms + reception + 01 office + lobby + internet cafe) Mezz. - (other portion in other use) 1 st floor – (11 guest rooms) 2 nd floor – (22 guest rooms) 3 rd & 4 th floor – (not in use as per affidavit dated 24.02.2025 regarding not to use any floor above second floor)		
3	Type of occupancy	Residential Sub Division-A-1		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/GH/NDZ/2022/149 dated 15.03.2022		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	22.02.2025		
8	Name of the inspecting officers	ADO (SPM)		
9	Name of the designation of officer from the building side	Mr. Vivek Juneja (Proprieter)		
10	Year of construction			
11	Applicant's letter no.	Online application no. 2025021701972 dated 17.02.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
	Road width	NA	06 m	NA
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	01 no.	MR
	b Basement	NA	NA	NA
	B Width of staircases			
	a Upper floor	0.80 mtrs.	1.05 mtrs.	MR
	b Basement	NA	NA	NA
	C Protection of exits			
	a Fire check door	Required	Provided	MR
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	NA	NA	NA
	E Width of corridor	NA	NA	NA
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Upper floors	12 ACPH	Exhaust fan	MR
	B Basements	NA	NA	NA

5.	Fire Extinguisher:				
	A	Total numbers	10 nos.	16 nos.	MR
	B	Types	CO ₂ & ABC	Provided	MR
	C	ISI marking	Required	Provided	MR
6	First-Aid-Hose Reels:				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection And Alarming System:				
	A	Type of detectors (CO type)	Required	Provided	MR
	B	Location of main panel	Required	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	Required	Provided	MR
	E	Hooters	Required	Provided	MR
8	MOEFA:		Required	Provided	MR
9	Public Address System:		Required	Provided	MR
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	B	Terrace level			
	a)	Discharge of pump	450 LPM	450 LPM	MR
	b)	Head of the pump	30 m	30 m	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage For Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	5,000 ltrs.	5,000 ltrs.
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		Required	Provided
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA
19	Fire Control Room :			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	Pa system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

The owner has submitted an affidavit on 24.02.2025 stating not to use any floor above 2nd floor for any purpose.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No F6/DFS/MS/GH/NDZ/2022/149 dated 15.03.2022 is recommended to be renewed upto 2nd floor only, under Rule 35 of the Delhi Fire Service Rules 2010.

[Signature]
27/02/2025
Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)

[Signature]
27/2/25

[Signature]
Dy. C.F.O. (202)

[Signature]
28/02/25

C.F.O.

[Signature]
28/2/2025

Director

[Signature]
28/02/25

[Signature]