



No. F6/DFS/MS/School/NDZ/2025/ 115

Dated: 04/02/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Vivekanand School** located at **F-Block, Preet Vihar, Delhi-92** comprised of **Ground + 02 Upper floors**, owned/occupied by **Vivekanand School** was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/NDZ/2022/128 dated 08/02/2022. The School building was re-inspected by the officers concerned of this department on 29/01/2025 in presence of Mrs. Bhavna Anand (Principal) and observed that all the fire prevention and fire safety requirements in the premises found in good working condition. The premises have therefore deemed complied with the Fire Prevention and Fire Safety requirements in accordance with Circular No. 262-362 dated 01.03.2011 issued by Director of Education and that the building is fit for occupancy class (**Group - B) "Educational Building"** with effect from 04/02/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions printed below.

Issued on 04/02/2025 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to:-**

1. The Commissioner of MCD, 419, Udyog Sadan, Patparganj, Delhi - 110092.
2. The Principal, Vivekanand School located at F-Block, Preet Vihar, Delhi-92.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".



### INSPECTION REPORT

1	Name & address of the building	Vivekanand School at F-Block, Preet Vihar, Delhi-92		
2	Building is comprised of	Ground plus two upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2022/128 dated 08/02/2022.		
6	Fire safety directives letter no.	262-362 dated 17/01/2005		
7	Date of inspection	29/01/2025.		
8	Name of the inspecting officers	Ashok Kumar Jaiswal, Divisional Officer / East & Yashwant Singh Meena, A.D.O / Laxmi Nagar		
9	Name of the designation of officer from the building side	Mrs. Bhavna Anand (Principal)		
10	Year of construction	1983		
11	Applicant's letter no.	Outdoor Dairy No. 11563 dated 20/01/2025		
S.N o	Minimum standard of fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
	A Road width	06 mtr.	08 mtr.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A Number of staircases			
	a Upper floor	02 no.	02 nos.	MR
	c Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.5 m	1.5 mtr. & 0.95 mtr.	MR (old accepted)
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	02 no.	01 nos.	01 nos.
	E Width of corridor	1.50 mtrs.	1.5 mtr.	1.5 mtr.
	F Door size	1.0 mtr.	1.0 mtr.	1.0 mtr.
3	<b>Compartmentation:</b>			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

u



<b>5. Fire Extinguisher:</b> - N/13-				
A	Total numbers	06 nos.	10 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	01 no	01 no	MR
B	Length of hose reel hose	30 m	30 m	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	Provided	MR
<b>10 Automatic Sprinkler System:</b>				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	1 no.	1 no.	MR
C	Hose box	1 no.	1 no.	MR
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13 Pumping Arrangements:</b>				
1	<b>Ground level</b>			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	<b>Terrace Level</b>			
A	Discharge of pump	450 LPM	900 LPM	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

N/14

## Vivekanand School at F-Block, Preet Vihar, Delhi-92.

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	30,000 ltrs. MR
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	5,000 ltrs	5,000 ltrs MR
15	Exit Signage:		Required	Provided MR
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			N/A

Note: Building is actually G +02 upper floors only. It may have been printing mistake in previous inspections.

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter F6/DFS/MS/School/NDZ/2022/128 dated 08/02/2022, renewal under the Circular no. 262-362 (Director of Education) dated 17.01.2005, is recommended.

No file is pending with me before disposal of this case.

Signature of the Inspecting Officer  
Name : Yaswant Singh Meena  
Designation: ADO /Laxmi Nagar

Signature of the Inspecting Officer  
Name: Ashok Kumar Jaiswal  
Designation: Divisional Office/ East

Dy. C.F.O (NDZ) R.V.P.  
31/10/25

C.F.O. / 31/10/2025

Director / 31/11/25

Adm/Kn

P.T.O