

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Indl./2025/SZ/ 58
To

Dated: 10/02/2025

Mr. Ashwani Mehta,
M/s VLS Finance Ltd.
Plot No 90, Okhla Industrial
Estate Phase-III, New Delhi 110020

Sub: Regarding issuance of Fire Safety Certificate in r/o **M/s VLS Finance Ltd.** located at Plot No 90, Okhla Industrial Estate Phase-III, New Delhi 110020

Sir,

This has reference with letter no nil dated 28/01/2025, received through outdoor diary no 11906 dated 28/01/2025 on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officer concerned of this department on 06.02.2025 in the presence of Mr. Ashwani Mehta to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Fire check door found damage at some places.
2. Smoke management system not provided.
3. First aid hose reel provided but found non-functional.
4. Automatic sprinkler system provided but found non-functional.
5. Terrace level fire fighting pump capacity 900 LPM provided but found non-functional.
6. Exit signage found removed at some places.
7. Pressurization of Lift lobby not working in the basement.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

[Handwritten signature] C