

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2025/SZ/ 405
To

Dated: 21/08/2025

The Authorized Signatory,
VSNL/TCIL Bhawan at Wireless Complex,
Greater Kailash-I, New Delhi 110048

Sub: Regarding issuance of FSC in r/o VSNL/TCIL Bhawan at Wireless Complex,
Greater Kailash-I, New Delhi 110048

Sir,

This has reference to your letter no nil dated 01/08/2025 received through outdoor diary no 4436 dated 01/08/2025 on the subject cited above. In this connection, this is to inform you that the above-mentioned premise was visited by the officers concerned of this department on 07.08.2025 in the presence of Mr. Sunil Jha to verify the fire safety measures installed in the building. Accordingly, fire safety arrangement was tested / checked and found following observation.

1. There is encroachment seem in 6 mtr wide road all around this building, which needs to clear for fire tender movement.
2. The Second staircase in basement is found closed with brick wall.
3. The Fire Check door found removed at some places.
4. Dedicated firefighting pump capacity 2800 LPM, Diesel Engine driven pump capacity 2800 LPM and Jockey pump capacity 300 LPM need to be installed.
5. Exit Signage found removed at some place.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg.) MCD, Green Park, Aurobindo Marg, New Delhi -16