

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No: F.6/DFS/MS/2025/WZ/524 To,

Dated: 17/06/2025

The Principal,

VSPK International School Juniors. Kailash Memorial Charitable Society,

Plot No. 12, FC-57, Road No. 44,

Pitampura, Delhi-110034.

Sub: -Regarding renewal of Fire Safety Certificate in r/o VSPK International School (Kailsah Memorial Charitable Society), Plot No. 12, FC-57, Road No. 44, Pitampura, Delhi- 110034.

Sir,

This has reference to your letter no. VSPKJ/D/03/2024-25 dated 17/04/2025 received through outdoor diary no. 760 dated 17/04/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 31.05.2025 to see the compliance of the requisite fire safety measures. Sh. Sandeep Kumar was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Basement, Stilt, Ground plus two upper floors. Your request for

renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional.

2. Terrace level pump not found in auto mode.

3. Exit signage's found removed at some places.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

Director Delhi Fire Service

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.