



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2025/SZ/ 117

Dated: 21 / 03 / 2025

To

Sh. Manoj Kumar,  
Dy. Chief of Protocol (Facilities),  
Ministry of External Affairs,  
Jawaharlal Nehru Bhawan, D-23,  
Janpath, New Delhi-110001

**Sub: Regarding issuance of Fire Safety Certificate in r/o VVIP Receptorium located at Air Force Station Palam, New Delhi-110010**

Sir,

Please refer to your letter No. DIII/551/02/2024 (H) dated 19.12.2024, received through outdoor diary No. 12304 dated 10/02/2025, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 11/03/2025 in the presence of Sh. Gurmeet Singh (AE-Elect.) to verify the availability & operability of fire safety measures. During course of inspection, the shortcomings observed are as below.

1. The first-aid hose-reel not provided, same shall be provided in each block.
2. The manually operated electrical fire alarm (MOEFA) not provided.
3. The internal hydrant & hose box not provided.
4. Terrace level fire pump of 450 LPM discharge capacity with 40-meter head not provided.
5. Overhead water tank of 20,000 liters capacity exclusively for firefighting not provided.
6. Adequate exit signage in the escape route to be provided.

In view of the above, issuance of Fire Safety Certificate cannot be considered. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Executive Engineer, Outer Delhi Division, CPWD, R.K. Puram, New Delhi.
2. The DCP Security (PM & HQ), Delhi Police, Bapu Dham, New Delhi.