

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F.6/DFS/MS/BP/2025/ **323**

Dated: **04/07** /2025

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi 110002.

Sub: Clearance from fire safety point of view in r/o W-29, Okhla Industrial Area, Phase - II, New Delhi - 110020.

Sir,

Please refer your ID No. 10120623 dated 23.06.2025 on the above cited subject. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of new construction of building at W-29, Okhla Industrial Area, Phase - II, New Delhi - 110020.

Following shortcoming is observed: -

1. FCD is not provided in staircase as per UBBL-2016/NBC Part-4, 2016.
2. FCD is not provided in lift lobby.
3. Overhead fire tank and terrace pump is not shown in plan as per NBC part 4, 2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Barg)
Director

011-23414000

5