

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/SZ/2026/ 223

Dated: 14 10/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s. Ware house Block-A (Existing) situated at Mustitil No. 13, Killa No. 16, Min. South (2-14), 17 Min. South (4-2), (5-15), Mustitil No. 28, Killa No. 4 min (1-14) of Revenue Estate of Village Samalkha Extn., Tehsil Vasant Vihar, New Delhi- 110037, comprised of basement, ground, first and second floor (Shed), owned/occupied by Mr. Shashi Vats, Mr. Dushyant Vats, Mr. Deepak Vats and Mr. Pawan Vats, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010, and building was inspected by the officer concerned of this department on dated 10.09.2026 in the presence of Mr. Deepak Vats, and found that the building is fit for occupancy Class- 'Storage' "Group-H" w.e.f. 14/10/2026 with a period of three years, in accordance with Rule- 36 unless renewed under Rule- 37 or sooner cancelled under Rule- 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 14/10/2026 at New Delhi.


(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Executive Engineer (Bldg) MCD, Najafgarh Zone Main Zonal Building. Dhansa Stand, Najafgarh, New Delhi-110043.
2. The Authorized Signatory, the M/s. Ware house Block-1 (Existing) situated at Mustitil No. 13, Killa No. 16, Min. South (2-14), 17 Min. South (4-2), (5-15), Mustitil No. 28, Killa No. 4 min (1-14) of Revenue Estate of Village Samalkha Extn., Tehsil Vasant Vihar, New Delhi- 110037.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The basement shall be used as per BBL/UBBL.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/41

INSPECTION REPORT

1.	Name & address of the building	Wearhouse at Mustitil No. 13, Killa No. 16, Min. South (2-14)17 min. South (4-2), (5-15), Mustitil No. 28, Killa No. 4 min (1-14) of Revenue Estate of Village Samalkha Extn., Tehsil Vasant Vihar, New Delhi- 37.		
2.	Type of Occupancy	Building Group H (Storage Building)		
3.	Building Comprised of	Block-1 (Existing Building)- Basement, ground, 1 st , and 2 nd floor (Shed). Block-2 (proposed)- Not yet constructed.		
4.	Type of Case	New Case		
5.	Details of previous NOC No.	N/A		
6.	Fire Safety directives Letter No.	F6/DFS/MS/BP/2026/48 dated 19.02.2026		
7.	Date of inspection	10.09.2026		
8.	Name of the Inspecting Officer	R.K. Yadav, ADO (DWK)		
9.	Name and designation of Officer from the building side	Mr. Deepak Vats		
10.	Year of Construction	2025-26		
11.	Applicant's letter No.	Form 'I' dated 10.08.2026		
Sr. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per BBL/UBBL	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	60.0 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 nos.	02 nos.	MR
	• Basements	02 nos.	01 nos. + 01 ramp	MR
	b. Width of staircases			
	• Upper floors	1.50 m each	1.68 m & 1.50 m	MR
	• Basements	1.50 m each	1.50 m & Ramp- 2.40 m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	02 nos.	02 nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basement.	12 ACPH	Provided	MR
	• Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	35 Nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			

9-

N/S/

	- Total numbers on each floor - Length of hose reel hose - Nozzle diameter	02 nos.	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection and alarming system.			
	- Type of detector - Location of Main Panel - Location of Repeater Panel - Alternate source of power - Hooters' Location	Smoke/Heat	Provided	MR
		Required	Provided at Ground floor	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		Appropriate place	Provided	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	- Basements - Upper Floor - Sprinkler above false ceiling	Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
11.	Internal Hydrants			
	- Size of riser/down- comer - Number of hydrants per floor - Hose Box	100 mm	Provided	MR
		02 nos.	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants			
	- Total number of hydrants - Hose Box	02 nos.	Provided	MR
		Required	Provided	MR
13.	Pumping Arrangements			
	- Ground Level ➤ Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access - Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump	2280 LPM	Provided	MR
		90 m	Provided	MR
		01 nos.	Provided	MR
		180 LPM	Provided	MR
		60 m	Provided	MR
		2280 LPM	Provided	MR
		90 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		450 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for firefighting			
	- Underground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank - Overhead Tank capacity	3,00,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 ltr	Provided	MR
15	Exit signage	Required	Provided	MR
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

7-


R76

17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	02 nos. ABC type fire extinguisher provided near electric panel	N/A


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.


Note: - As per Affidavit submitted by owner's (placed at C- 24) that the said property there exists Block A (Existing Building) comprised of basement, ground & first floor and a shed at the second floor admeasuring 365.43 sq.m. **The proposed Block B has not been constructed as on date and shall be constructed subsequently.**


Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules **it is recommended to grant Fire Safety Certificate** under Rule 35 of the Delhi Fire Service Rule 2010.


 Signature of the Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (DWK)


DO (SW)


 14/9/26


 P1. Spear


 16/09/2026
 DO (SW) + ADO (DWK) **Debabrata Mukherjee**

Resubmitted as directed.




 21/9/26


 29/09/2026
Debabrata Mukherjee

Conceded:-