

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Storage/2025/SZ/227  
To

Dated: 19/05/2025

The Executive Engineer (Bldg) HQ,  
Municipal Corporation of Delhi,  
9<sup>th</sup> floor, Civic Center, Minto Road,  
New Delhi 110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Warehouse at Mustatil No 17, Kila No 16/1 (1-16), 16/2, (1-6), 25 Min (3-18), 26 (0-13) Mustatil No 20, Kila Nos 5 Min (4-9) and 6 Min (4-9), 31//15/2 (5-1) Previous record as Khasra No 31//15-16(5-1) Village Bannoli Bijwasan New Delhi

Sir,

This has reference with **online ID 10114475 dated 07/05/2025** on the subject cited above. In this connection, it is to inform you that the premise has been Joint inspected by officers concerned of this department on 13.05.2025 along with Mr. Sushil Kumar AE/Bldg MCD & Mr. Rakam Singh Meena JE/Bldg MCD to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. The Compartmentation of warehouse not done.
2. Terrace level fire fighting pump capacity 450 LPM not provided at the terrace of warehouse.
3. Overhead tank capacity 10,000 ltrs not provided at the terrace of warehouse.
4. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

01/06/25