

c96

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/GH/2025/SZ/ 227

Dated: 22/04/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Waves Guest House at A-272, Mahipalpur, NH-8, New Delhi- 110037, comprised of, basement (parking & storage), ground floor (reception & 07 guest rooms), 1st & 2nd floor each having 13 guest rooms respectively (total 33 guest rooms only) & 3rd floor used for owner residence, was issued FSC by this department vide letter No F.6/DFS/MS/GH/2022/SZ/395 dated 26.08.2022. The premises was re-inspected by the officer concerned of this department on dated 16.04.2025 in the presence of Sh. Manoj Kumar and found that the guest house have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi fire service Rules 2010 and that the building/premises is fit for occupancy class "Residential" (Guest house) (33 guest rooms at ground, 1st & 2nd floor) w.e.f. 22/04/2025 and valid up-to 31.03.2028, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 22/04/2025 at New Delhi.


(Atul Garg)
Director
Delhi Fire Service
@/48

Copy to: -

- 1 The Commissioner, MCD, Delhi: with a request to ensure the occupancy as detailed above and deviation, if any.
- 2 Online application Id 2025032104208 dated 24.03.2025.
- 3 The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi.

: - for information regarding use of basement.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws. Presently basement used for parking & storage purpose.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. Waves guest house at A-272, Mahipalpur, NH-8, New Delhi- 110037.
2. Building is comprised of : Basement, ground plus three upper floors,
3. Type of Occupancy : Residential (Guest House)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/GH/2022/SZ/395 dated 26.08.2022
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 16.04.2025
8. Name of the Inspecting officers : ADO R.K. Yadav (JKP)
9. Name and designation of officer from the building side : Sh. Manoj Kumar
10. Year of construction : 2003
11. Applicant's letter No : ID No. 2025032104208 dated 24.03.2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	06 m	MR
	• Gate width	80 ft. main road	80 ft. main road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 Nos.	02 Nos. (B, G to 3 rd F) & 01 spiral (B to terrace)	MR, old case
	• Basement	02 Nos.	01 stair + 01 Ramp	MR, old case
	B. Width of Staircases			
	• Upper floor	1.25 m	1.05 & 0.75 m (iron stair)	MR, old case
	• Basement	1.25 m	1.05 m + ramp- 2.8 m	MR, old case
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of Continuous Staircases to Terrace	01	01	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floor	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	10 nos.	Provided	MR
	• Types	ABC /CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

N/27

16

Pr

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection, CO detection and Alarming System.			
	• CO Type of detectors	Co/type	Provided	MR
	• Location of main panel	Required	Provided at GF	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided at each floor	MR
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement & Stilt	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	01	N/A
	• Hose box	N/A	01	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 ltrs	5,000 ltrs	MR, old case
15	Exit Signage.	Required	Provided	MR

N/28

	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/NDZ/2025/GH/163 dated 09.04.2025 have been rectified.

Note: - As per undertaking given by guest house management (placed at C-94) that the building comprised of basement, ground plus three upper floors, using basement for parking & storage purpose only, ground floor (reception & 07 guest rooms), 1st & 2nd floor each having 13 guest rooms respectively (total 33 guest rooms only) & 3rd floor is used for owner residence.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/GH/2022/SZ/395 dated 26.08.2022, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (SD)

[Signature]
CFO (JKP)
21/4/25
21/4/25

[Signature]
आपका यह कार्य ठीक है
आपका यह कार्य ठीक है
आपका यह कार्य ठीक है
आपका यह कार्य ठीक है