

2/85

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2025/ 94/163

Dated: 09/04/2025

To

The Manager,  
M/s Waves Guest House,  
A-272, Mahipalpur, NH-8,  
New Delhi 110037.

Sub: Regarding issuance of FSC in r/o M/s Waves Guest House at A-272, Mahipalpur, NH-8, New Delhi 110037.

Sir,

This has reference to online id no. 2025031703648 dated 17/03/2025, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 02/04/25 in the presence of Mr. Manoj Kumar Lohia and following shortcomings were observed:-

1. PA system found nonfunctional.
2. Detector found non functional.
3. Pump not in auto mode provision.
4. Building plan as uploaded on the portal does not match with existing profile of guest house, request to upload the complete set of sanctioned /as built building plan with duly signed by the architect and owner/ occupier of the guest house .

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

**Copy to :-**

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.