



C/59

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

No. F6/DFS/MS/Metro/2025/NDZ/ 337

Dated: 23/06/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Welcome Metro Station, Line-1, Delhi, comprised of ground level and platform level owned/occupied by Delhi Metro Rail Corporation was issued FSC vide letter No. F.6/DFS/MS/Metro/2022/NDZ/257 dated 14/06/2022. The premises was re-inspected by the officer concerned of this department on 11/06/2025 in the presence of Mr. Pushkar Singh, (AM/Fire) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class 'Assembly' (class "D") with effect from 23/06/2025 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 23/06/2025 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

To,

The Sr. DGM/E&M  
Metro Bhawan 13 Fire Brigade Lane  
New Delhi 110001

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : Welcome Metro Station, Line-I, Delhi,
2. Building is comprised of : Ground/Concourse Level Platform Level
3. Type of Occupancy : Assembly Building
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/Metro/2022/NDZ/257 dated -14/06/2022
6. Fire Safety direction letter No. : F.6./DFS/MS/BP/2003/209 Dated 27/01/2003
7. Date of Inspection : 11/06/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Pushkar Singh, (AM/Fire)
10. Year of Construction : 2003
11. Applicant's email ID : DMRC/O&M/Fire/NOC/L-1/2025/09 dated 15/04/2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive, Required	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> <li>Road width</li> </ul>	06 mtr.	20 mtr.	MR
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Gate width</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>			
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>Upper floor</li> </ul>	04 nos.	04 nos.	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>Upper floor</li> </ul>	02 mtr.	2.40 mtr. each	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	04 nos	04 nos	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Fire rating of shaft door</li> </ul>	02 hrs.	02 hrs.	MR
	<ul style="list-style-type: none"> <li>Water curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire dampers</li> </ul>	N/A	N/A	N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floor</li> </ul>	N/A	N/A	N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	30 nos.	30 nos.	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marked	ISI marked	MR



06	First-Aid-Hose Reels.			
	Total numbers on each floor	04 nos	04 nos	MR
	• Length of hose reel hose	30 m	45 m	MR
	• Nozzle diameter	5 mm	6.5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Heat or Smoke	Provided	MR
	• Location of main panel	Ground Level	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	04 nos.	04 nos.	MR
	• Hose box	04 nos.	04 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			MR
	• Discharge of main pump	1620 LPM	2400 LPM	MR
	• Head of main pump	60 mtr	60 mtr	MR
	• Number of main pumps	01 no.	01 no.	MR
	• Jockey pump out put	180 Lpm	180 Lpm	MR
	• Jockey pump head	60 m	60 m	MR
	• Standby pump out put	1620 Lpm	2400 Lpm	MR
	• Standby pump head	60 mtr	60 mtr	MR
	• Auto starting /manual stopping	Auto	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			N/A
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	1,00,000 Ltrs.	1,00,000 Ltrs.	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection system provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule. The FSC issued vide letter No. F6/DFS/MS/Metro/2022/NDZ/257 dated -14/06/2022 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

*Deepak*  
11/06/2025.  
Signature of the inspection Officer  
Name :- Deepak Kumar  
Designation :- A.D.O (Shd)

DO(ED)

*Deepak*  
12/06/2025  
Dy. C.F.O (NDZ)

*Rimp*  
12/06/25

C.F.O.  
13/6/2025

Director  
12/6/25

12/6/25

Sir, F.T. letter is put up for your kind signature pl.

*Deepak*  
19/06/2025  
P.T.O