



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



No. F.6/DFS/MS/BP/Hospital/2025/163

Dated: 16/04/2025

To,

The Chief Architect,
Region Delhi, CPWD,
Room No. 217-218,
'A' Wing Nirman Bhawan,
New Delhi-110001

Sub:- Approval of building plans from fire safety point of view in r/o WUS Health Centre at 1 B9, Chhatra Marg, North Campus, Delhi University, New Delhi.

Sir,

With reference to online request no. ADG PROJECT DELHIREGION20240416/2361 dated 24.03.2025 on the subject cited above, it is informed that the observations already issued vide letter No. F.6/DFS/MS/BP/Hospital/2025/62 dated 11.02.2025 have not been complied in totality (Copy of the same is enclosed for reference) and additionally, following shortcomings are also observed:-

1. Fire pump house is not proposed as per UBBL 2016/NBC 2016 Part-IV.
2. Dead end travel distance is not proposed as per clause 7.8.2 of UBBL-2016/ NBC-2016, Part- IV.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcoming for further consideration in the matter.

Yours faithfully,

(Atul Garg)
Director

[Signature]
c. A. J.