



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/WZ/Motel/2026/ 101

Dated:- 09/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi -110002.

Sub.:- Regarding renewal of Fire Safety Certificate in r/o M/s. Yadu Pratishtha Hall & Ornate Hall,
Located at Yadu Green Motel, Kh. No. 42/25, 52/9, 52/10, 52/11, 53/5, 53/6 min, Village
Bakoli, Main GT Karnal Road Delhi- 110036.


Sir,

This has reference to MCD online application no. 2026031202790 dated 14/03/2026, on the subject cited above. In this connection, it is to inform you that the above said building was re-inspected by the officers concerned of this department on dated 23/03/2026 in the presence of Sh. Lalit Kumar, GM & Sh. K. N. Chaudhary, Mngr. (F&B) to check the Fire Safety measures provided in the building. During course of inspection following shortcomings were observed:-

1. Smoke management system provided in the halls found removed.
2. Hose reel hose found non-functional.
3. Detection system of both halls and main panel found non-functional.
4. MOEFA found non-functional.
5. Public address system found non-functional.
6. Many sprinkler heads found covered by false ceiling in Pratishtha Banquet Hall.
7. Yard Hydrant system found non-functional.
8. All Pumps of Pump house and terrace pump found non-functional and not on auto mode.
9. Draw-off connection in underground water tank is not provided.
10. Stand-by power supply is not provided.

In view of above, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


08/04/26

S.K. Dua

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy to:-

1. M/s. Yadu Pratishtha Hall & Ornate Hall, Located at Yadu Green Motel, Kh. No. 42/25, 52/9, 52/10, 52/11, 53/5, 53/6 min, Village Bakoli, Main GT Karnal Road Delhi- 110036.