



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No:F.6/DFS/MS/GH/2025/NDZ/ 246

Dated: 21/05/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st Floor,
Police Station, Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o You & Me Guest
House located at 4459- 4462, Katra Raiji, Pahar Ganj, Delhi- 110055.

Sir,

This has reference to online application received through MCD portal vide ID- 2025050708083 on the subject cited above. In this connection, it is to inform you that the above said residential building was re-inspected by officer concerned of this department on 15/05/2025 to see the compliance of requisite fire safety measures. Smt. Manju Sharma was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. First aid hose reels found provided but not functional.
2. Carbon monoxide detectors found removed at some places.
3. Terrace level pump not found in auto mode.
4. Exit signage's found removed at some places.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. The owner/ occupier, M/s You & Me Guest House located at 4459-4462, Katra Raiji, Pahar Ganj, Delhi- 110055.
2. MCD Portal ID No. 2025050708083.