

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2025/296

Dated:-20/06/2025

To

The Commissioner, MCD,
Civic Center, New Delhi.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o Multistoried Academic Tower at Zakir Husain Delhi College Jawahar Lal Nehru Marg, New Delhi.

Sir,

This has a reference to online id no. 10117714 dated 12.06.2025, on the subject cited above. In this regard, this is to inform you that the site was inspected by the officer concerned of this department on 17/06/2025 in the presence of Mr. Rahul Rana JE (B) MCD & Dr. Manish, Professor, Zakir Hussain from building side and following shortcomings were observed:

1. 06 meter all around road for fire tender movement found obstructed due to branches of trees fall on the way.
2. Pressurization of staircase, lift lobby & shaft found nonfunctional.
3. Detectors found nonfunctional at some places.
4. Hose reel & hydrant found nonfunctional due to leakage in hydrant line.
5. Smoke management system found nonfunctional.
6. PA system & MOEFA found nonfunctional.
7. Pumps not in auto start provision.

In view of above, the case is rejected with a request to rectify the above shortcomings immediately. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Gang)
DIRECTOR

01123414000

19/6

Copy to :

Authorized Signatory, Multistoried Academic Tower, Zakir Husain Delhi College,
Jawahar Lal Nehru, Marg, New Delhi.