

C 87

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/2025/*coll-ge/62*

Dated *27/05/2025*

To,

Prof. Narendra Singh (Principal),
Zakir Hussain College at Jawahar Lal Nehru Marg,
Near MCD Civic Center, Delhi - 110002.

Sub:-Regarding renewal of FSC in r/o Auditorium at Zakir Hussain College at Jawahar Lal Nehru Marg, Near MCD Civic Center, Delhi - 110002.

Sir,

This has reference to your letter no. ZHC:PO:115:133 dated 03.04.2025, on the subject cited above. In this regard the site was inspected by the officer concerned of this department on 16/05/2025 in the presence of Sh. Sourav and the following shortcomings were observed:-

1. Smoke detectors found nonfunctional at some places.
2. Fire extinguishers found due for refilling.
3. Hydrant coupling found missing from the some hydrant.
4. PA system found non functional
5. One pump of 900 LPM found nonfunctional.
6. Fire service inlet & draw of connection found nonfunctional.

In view of above shortcomings, the application for renewal of FSC is rejected. The occupancy in the building in absence of requisite fire safety arrangements shall be at risk and liability of owner /occupier. Further, statutory authority / building sanctioning authority may take necessary action as deemed fit.

Yours faithfully

(*Am*) Garg)
DIRECTOR

Delhi Fire Service
27/05/25

Copy to:-

1. The Principal, Zakir Hussain College, Jawahar Lal Nehru Marg, Near MCD Civic Center, Delhi-110002.