

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2025/SZ/ 262

Dated: 12/06/2025

To,

The Joint C.P. (LIC.),
1st floor, Police Station,
Defense Colony, New Delhi.

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o M/s Zoroco Restaurant (A unit of Zoroco Hospitality) at Plot No. 59, 2nd floor, Rama Road, Industrial Area, Moti Nagar, New Delhi- 110055.

Sir,

Please refer to online application ID 2025051608610 dated 19.05.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the aforesaid eating house building on dated 04.06.2025 in presence of Mr. Akram, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the above said eating house/restaurant running at 2nd floor only in a building comprised of ground plus two upper floors, and have following shortcomings: -

1. Two staircases with having width of 1.50 & 1.35 to 2.0 m found provided against requirement of two staircases having clearcut width of 1.50 m each.

Keeping in view of above, issuance of fire safety certificate can-not be considered at this stage. Management of the restaurant may be requested to rectify the above said shortcoming for taking further necessary action in this matter under intimation to this department and running restaurant/eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Owner/Occupier, M/s Zoroco Restaurant (A unit of Zoroco Hospitality) at Plot No. 59, 2nd floor, Rama Road, Industrial Area, Moti Nagar, New Delhi- 110055.
2. The Executive Engineer (Bldg.), MCD, Civic Centre, Minto Road, New Delhi- 110002. : - for necessary action please.